

CERTIFICATE OF CONSTANCY OF PERFORMANCE

2649-CPR-26001302

CE CONFORMITY

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s) Reference: Single Leaf Single Action Swing Wooden Door
Intended use: Fire/smoke compartmentation and/or escape routes
Product(s): GUANGDONG YOHOME - CE Wooden Fire Doorset (model YHCEFD60) - CE
Spec ID: 91686
Listing Information: See following page(s)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):
EN 14351-1:2006+A2:2016/ EN 16034:2014

Placed on the Market under the name of: Guangdong Yohome Door Co., Ltd.
Room 1101, 11th Floor, Ruiheng Science and Technology Innovation Park
No. 20 Juyuan South Road, Guicheng Sub-district, Nanhai District
Foshan, Guangdong 528299
China

And produced in the manufacturing plant: 5029350

Under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product

This certificate was first issued on May 15, 2026 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The issued document and statement(s) herein makes reference only to a presumption of conformity in accordance with the CPR Regulations EU 305/2011 (as amended). However, it is the manufacturer's or their authorised representative's sole responsibility to affix the CE logo and, by doing so, confirms full compliance and conformity to all other European mandatory directives and regulations that may also apply



Notified Body
NB 2649

Signature:

Initial registration Date: May 15, 2026

Name: Pedro Cabezuelo del Pozuelo

Expiration Date: December 31, 2026

Position: Certification Manager NB

Issue Status: 1

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

LISTING INFORMATION

Product Description:

Single Leaf Single Action Swing Wooden Fire Door and Wooden Frame Assembly

Under **System 1** for the performances set out in this certificate are applied and that the performance of the construction product fulfills all the prescribed requirements as per TABLE 1 and TABLE 2.

Product Name: CE Wooden fire doorset

Model Ref: YHCEFD60

Brand: YOHOME

TABLE 1. ZA.1 Clauses for external pedestrian doorsets from GUANGDONG YOHOME DOOR CO., LTD.

Product: External pedestrian doorsets by the scope of EN 14351-1.		
Intended uses: Fire/smoke compartmentation and escape routes.		
Essential Characteristics	Requirement clauses	Results
Resistance to wind load	Load-bearing capacity and deflection against wind	NPD
Resistance to snow and permanent load	Load-bearing capacity against snow and permanent load	NPD
Reaction to fire	Reaction to Fire performance in accordance with EN 13501-1	NPD
External fire performance	External Fire performance in accordance with EN 13501-5	NPD
Watertightness	Watertightness performance in accordance with EN 12208	NPD
Dangerous substance	Release dangerous substances	No dangerous substances declared for this product
Impact resistance	Impact resistance in accordance with EN 13049	NPD
Load bearing capacity of safety devices	Load bearing capacity of safety devices	NPD
Height and width	Clear opening height and width in mm	Height: Up to 2405 mm Width: Up to 1010 mm
Ability to release	Reliable closing of a doorset and/or openable window in the event of fire and/or smoke or power supply failure	NPD
Acoustic performance	Sound insulation performance in accordance with EN ISO 717-1	NPD
Thermal transmittance	Thermal transmittance	NPD
Radiation properties	Total solar energy transmittance and light transmittance of translucent glazing	NPD
Air permeability	Air Permeability	NPD

*NPD- Non Performance Declared

TABLE 2. ZA.1 Clauses for fire resistance and/or smoke control doorsets from GUANGDONG YOHOME DOOR CO., LTD.

Product: Fire resistance and/or smoke control doorsets by the scope of EN 16034.		
Intended uses: Fire/smoke compartmentation and on escape routes.		
Essential Characteristics	Requirement clauses	Results
Resistance to fire (for fire compartment uses)	Capability to provide “integrity” (E), “integrity and insulation” (EI1, EI2) or “integrity and radiation” (EW)	EI260
Smoke control (only for applications where limitation of smoke spread is required)	Capability to prevent smoke leakage at ambient (S_a) or medium temperature (S_{200})	S_{a4} S_{200}
Ability to release	Reliable closing of a doorset and/or openable window in the event of fire and/or smoke or power supply failure	NPD
Self-closing	Ability to close fully without human intervention	C
Durability of self-closing	Against degradation (cycling testing)	3
	Against ageing (corrosion)	achieved

*NPD- Non Performance Declared

Single Leaf Single Action Swing Wooden Fire Door and Wooden Frame.

Fire resistance (Door): max. height 2410 mm, max. width 1034 mm and max. area 2.492 m².

Smoke control (Door): max. height 2410 mm, max. width 1034 mm and max. area 2.492 m².

For detailed information about the doorset and conditions for classification, see Listing Report file (Spec ID: 91686).

END OF DOCUMENT