

Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek WH US + C Mark for Category B - Doors - Additional Edge-sealing System Required

Standards: CAN / ULC S104 (2015) (R2020), UL 10(b) (2008) (R2020), UL 10(c) (2016) Ed. 3 (R:27 May 2021), NFPA 252 (2022)

Certificate number: WHI24-42597305

Organization: Guangdong Yohome Door Co., Ltd.
Room 2108-1, Floor 21, Building 4, Jiabang Guojin Center
No. 1, Shilong South Road, Guicheng Street, Nanhai District,
Foshan, Guangdong 528299
China

Product: YOHOME - 60 MINUTES FIRE RATED DOOR (MODEL YH-02)

Spec ID: 77457

Fire Rating: 60 Min PP Category B Door


Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: April 10, 2024

Date of expiry: December 31, 2026

Issue status: 3

Authorized By: 

Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.

545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA

Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

FIRE RESISTANT PRODUCTS & COMPONENTS

CATEGORY B DOORS - ADDITIONAL EDGE - SEALING SYSTEM REQUIRED

A self-adhesive Category G intumescent perimeter seal system applied to frame is required.

PRODUCT COVERED

YOHOME 60 Minutes Single Leaf Wooden Fire Door with Hose Stream

Model: YH-02

PRODUCT DESCRIPTION

Hardware Limitations:

Listed Mortise Locks or Cylindrical Lock with minimum latch bolt throw of 1/2".

Minimum one single point standard latching on the leaf.

Configuration

Single

Standard Pairs

Double Egress

Maximum Size

1024 mm × 2405 mm (W × H)

Not allowed.

Not allowed.

This door is eligible for use with YOHOME 60 minutes Fire Rated Door Frame (Model YH-02).

The product noted above has been tested and qualified per UL 10B, UL 10C, NFPA 252, and CAN / ULC S104 for a 60 Minute Positive Pressure Fire Rating with Hose Stream.

The door noted above is eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.